

Complete Asset Automation & Management System



Enclosures Guide

Standard System Enclosure



N.B. The wall surface must be flat and level and free of extrusions that would interfere with the installation of the equipment enclosure

Lighting Control Panel Enclosure

N.B. the LCP 4 and LCP 8 are the same external dimensions



Recommended minimum space including clearance is 700mm(H) x 500mm(w)

N.B. The wall surface must be flat and level and free of extrusions that would interfere with the installation of the equipment enclosure flat against the wall.

External Equipment Enclosure Examples



CAAMS and LCP Enclosures housed in a medium size freestanding switchboard enclosure



CAAMS Enclosures housed in a small size freestanding switchboard enclosure with custom key switches located on the side of the switch board enclosure*

*N.B. the customisation of the switchboard enclosure and the key switches was done by the electrical contractor

CAAMS and LCP enclosure housed in a large switchboard in a separate section



Example of a recommend CAAMS Enclosure installation



Note - The Larger Enclosure is not included in the CAAMS Proposal and would be installed by the Client as part of the Installation Pre-Works

Technical Support

Complete Security Solutions

Unit 22, 105-119 Newcastle St
FYSHWICK ACT 2609

1300 79 14 15

projects@completesecurity.com.au
www.completesecurity.com.au

